



Remote control panel configuration



Comments: 1. Dashed network connection (Standard CAT 5/6 Ethernet cable) provided by others. 2. It is not recommended to connect MOXA switch to buildings subnet. Doing so may cause communication problems between both the host HMI and remote HMI to the host PLC. 3. Once connected, user can control the process chiller using either the host HMI (located in the chillers control compartment) or the remote HMI located on the wall mounted remote control panel.

	Networking design subject to change without notice			
	Copyright – 2013, Legacy Chiller Systems, Inc.			
Drawn by: Mking	SIZE NA	FSCM NO NA	DWG NO NA	REV 1
Rev date: 9-28-13	SCALE	NONE	SHEET	1 OF 1